

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
KC Public School
Akhnoor Road, Jammu

No: JDF&ES/FPI/ 6176
Sub: Fire Safety Certificate.
Ref: Your letter dated 23.10.2019.

Dated: 5.11.2019

Dear Sir,

The spot inspection of the above noted School has been got carried out. The detailed report of which is as under:-

LOCATION / ACCESSIBILITY:

The School building is located at Akhnoor Road, Paloura Jammu. The site is about 02 km away from Fire & Emergency Station Canal and is approachable for fire tenders in case of any emergency.

DETAIL OF BUILDING:

The school having two blocks in which one is triple storey with basement and another is double storied.

MEANS OF ESCAPE:


The main building (i.e. senior wing) has four numbers of internal open type staircases. Besides the building (i.e. junior wing) have two numbers of internal open type staircases.

EXISTING FIRE FIGHTING SYSTEM:


At present sufficient numbers of First Aid Fire Extinguisher, Hose Reel Hoses and water storage tank are available in the school premises. As such, the management can proceed ahead for running the school subject to adopting the following fire safety precautionary measures in letter and spirit:-

1. All exits/staircase should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
2. First Aid Fire fighting system installed in the School building should be checked periodically. Staff and students should be fully trained in handling/ operating of fire fighting system installed in the School building. The management shall intimate the office of Deputy Director, Fire & Emergency Services Command Jammu after each quarter that the fire fighting equipments installed in the school are functioning.
3. No Hazardous material should be kept inside or outside of the School premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, the clearance will be treated withdrawn/cancelled.
4. No addition/alteration should be made by the school management in the existing structure without prior permission from this department.
5. The validity of this clearance shall remain in force for three years. The management shall approach this office yearly for checking of fire fighting system installed in the entire school building.

K C Educational Society


Chairman Attested
Alisha
Principal
KC Public School, Jammu

Yours sincerely


Joint Director
Fire & Emergency Services
Jammu Range, Jammu